

RCM - Limit Switch Type EX

INSTALLATION INSTRUCTION


II-0006-RCM-I S-FX-FN

Revision: 22K15

Instruction:

- Mount facing centre of protected area.
- Rotate (2) for rotation to allow for installation of bolts. Use manual override handle (3) or 17mm socket wrench. (Remove tools after use)

DO NOT rotate motors to a point which makes the limit switches get in contact with domed cap nuts as seen below. Take care not to rotate the monitor in a way that strains the monitor or any surrounding equipment.



- Junction box without mount is to be placed no longer than 1m from monitor. Cable glands pointing down.
- Junction box with mount is to be fixed under connecting flange with one of the monitors bolts.
- The monitor should be supported by struts close to the connecting flange to make sure that reaction forces does not compromise the piping system.
- Do not rotate motors for elevation and nozzle before commissioning.
- **READ OPERATION AND MAINTENANCE MANUAL BEFORE POWERING ON THE MONITOR**

