


Instruction:

- Mount according to above working principle with arrow on API unit indicating flow direction pointing towards pump inlet.
- API Unit should be installed at a total maximum of 15 meters or 50 feet (A+B) to pump suction side.



PARTS LIST, STANDARD

POS	API-25	API-65 DIN/ANSI	API-100 DIN/ANSI
1 (Water Inlet/Outlet)	1" BSP Male	Flange, DN65 PN16 / 2½" 150 lbs	Flange, DN100 PN16 / 4" 150 lbs
2 (Foam Inlet)	1" BSP Female	Flange, DN50 PN16 / 2" 150 lbs	Flange, DN80 PN16 / 3" 150 lbs

PARTS LIST, INSTALLATION KIT

API-25	API-65 DIN/ANSI	API-100 DIN/ANSI
N/A	Bolt, 20x M16x80 ISO or 12x 5/8x3 UNC	Bolt, 16x M16x80 ISO or 16x 5/8x3 UNC Bolt, 8x M16x50 ISO or 4x 5/8x1 3/4 UNC
N/A	2x Gasket DN65, 1x Gasket DN50	2x Gasket DN100 1x Gasket DN80
N/A	Washer, 20x M16 ISO or 12x 5/8 UNC	Washer, 24x M16 ISO or 20x 5/8 UNC
N/A	Nut, 20x M16 ISO or 12x 5/8 UNC	Nut, 16x M16 ISO or 16x 5/8 UNC